



BSI Online, Inc.
PO Box 246
Worth, IL 60482

Official Receipt

Advanced Backflow LLC
4550 W. 90th Ave.
Westminster, CO 80031

Transaction Date: **May 6th, 2026**

Dear Advanced Backflow LLC,

Thank you for your report submittal. Copies of each report are attached for your records. Should you have any questions, please contact BSI Online, Inc. at 800-414-4990.

Submittal Information:
Reports submitted by Advanced Backflow LLC for:

Item Type	Device	Address	Passed?	Cost
Backflow Test	H01543	6600 Owl Lake Dr, Firestone, CO 80504-5450	PASS	\$16.95
Backflow Test	166297	6700 Owl Lake Dr, Firestone, CO 80504-3405	PASS	\$16.95
Backflow Test	J09451	6720 Owl Lake Dr, Firestone, CO 80504-3405	PASS	\$16.95
Backflow Test	J005185	6735 Owl Lake Dr, Firestone, CO 80504-9670	PASS	\$16.95
Backflow Test	122135	6750 Owl Lake Dr, Firestone, CO 80504-3405	PASS	\$16.95
Backflow Test	H34997	6755 Owl Lake Dr, Firestone, CO 80504-9670	PASS	\$16.95
Backflow Test	A239719	6760 Owl Lake Dr, Firestone, CO 80504-3405	PASS	\$16.95
Backflow Test	270925	9005 Owl Lake Dr, Firestone, CO 80504-5464	PASS	\$16.95
Backflow Test	A146950	9010 Owl Lake Dr, Firestone, CO 80504-5462	PASS	\$16.95
Backflow Test	A268468	9040 Owl Lake Dr, Firestone, CO 80504-5462	PASS	\$16.95
Backflow Test	H51895	9070 Owl Lake Dr, Firestone, CO 80504-5462	PASS	\$16.95
Backflow Test	H01604	9095 Owl Lake Dr, Firestone, CO 80504-5464	PASS	\$16.95
Backflow Test	A165814	9100 Owl Lake Dr, Firestone, CO 80504-5462	PASS	\$16.95

Paid From Balance: **\$0.00**

Paid From Credit Card (Visa:XXXX1011): **\$220.35**

Paid from BSI Credit: **\$0.00**

Total Transaction Fee: \$220.35

Thank you again for your submittal and for helping to protect against the dangers of cross-connections and backflow incidents.

Sincerely,

BSI Online, Inc.



BSI Online, Inc.
PO Box 246
Worth, IL 60482

Official Receipt

Advanced Backflow LLC
4550 W. 90th Ave.
Westminster, CO 80031

Transaction Date: **June 4th, 2026**

Dear Advanced Backflow LLC,

Thank you for your report submittal. Copies of each report are attached for your records. Should you have any questions, please contact BSI Online, Inc. at 800-414-4990.

Submittal Information:
Reports submitted by Advanced Backflow LLC for:

Item Type	Device	Address	Passed?	Cost
Backflow Test	J062107	9125 Owl Lake Dr, Firestone, CO 80504-5468	PASS	\$16.95
Backflow Test	J089514	6715 Owl Lake Dr, Firestone, CO 80504-9670	PASS	\$16.95
Backflow Test	J146453	6765 Owl Lake Dr, Firestone, CO 80504-9670	PASS	\$16.95

Paid From Balance: **\$0.00**

Paid From Credit Card (Visa:XXXX1011): **\$50.85**

Paid from BSI Credit: **\$0.00**

Total Transaction Fee: \$50.85

Thank you again for your submittal and for helping to protect against the dangers of cross-connections and backflow incidents.

Sincerely,

BSI Online, Inc.

13- 5/6/26 (young owl Lake)
3- 6/1/26 " "

$$5/1/26 + 6/1/26$$

Add.	Model	Size	Serial	Location	PSI	#1/CK	#2/AL	RV	Repair/Parts/Retest	Time	SOV
6600	860	1"	H01543	OUTSIDE NE CORNER	65	7.1	T	2.9			0
6700	LF009M2 QT	1"	166297	OUTSIDE NORTH WALL	45	7.8	T	3.7			0/c
6715	825Y	1"	J089514	L SIDE OF HOUSE, YARD NEAR HOT TUB	50	8.0	T	2.4			c/o
6720	825Y	1"	J094951	FRONT OF HOUSE	70	8.8	T	7.6			c/c
6735	825Y	1.5"	J005185	BY METER	45	7.4	T	2.8			c
6750	009M2QT	1"	122135	OUTSIDE EAST WALL	65	7.1	L	2.0	#1 repair RT 3.1 (A3) 887792		c
6755	860	1"	H34997	OUTSIDE BETWEEN HOUSE & STREET SURROUNDED BY BUSHES	65	7.6	T	3.0			0
6760	825Y	1"	A239719	OUTSIDE SOUTH WALL	65	6.5	T	3.0			c/o
6765	825Y	1"	J146453	OUTSIDE SE CORNER	80	8.4	T	2.1			c/c
9005	009M3QT	.75"	270925	OUTSIDE NORTH WALL	95	8.2	2.6				c
9010	805Y	.75"	A146950	IN PIT SOUTH OF DRIVEWAY	75	7.3	T	3.2			c/o
9040	825Y	1"	A268468	OUTSIDE NE CORNER	70	7.6	T	3.5			0/c
9070	825Y	1"	H51895	R OF FRONT DOOR	70	7.3	T	7.3	cleaned RV 3.1 (A3)		c/c
9095	860	1"	H01604	OUTSIDE BETWEEN HOUSE & STREET	45	7.6	T	3.0			c
9100	825Y	1"	A165814	OUTSIDE NE CORNER	70	5.9	T	2.3			c/o
9125	8A	1"	new	center front yard Job 2107	8.6	T	3.4	new			c/c
6745	009M2QT	.75"	174993	CAPPED/REMOVED							
9035				CAPPED/REMOVED							
9130	825Y	.75"	H11417	CAPPED/REMOVED							
9160	825Y	1"	A256652	CAPPED/REMOVED							